



LAKE REGION VILLAGE

July 2026 Newsletter

31850 U.S. Highway 27 South

Haines City, FL 33844

Have You Gotten Your Affairs in Order?

None of us likes to think about difficult situations or unexpected events, but planning ahead is one of the greatest gifts we can give ourselves and our loved ones. Organizing your important affairs can bring peace of mind and spare your family unnecessary stress during an emotional time.

Consider reviewing or preparing documents such as:

A current will or trust.

Healthcare directives and living wills.

Durable powers of attorney.

Beneficiary designations on financial accounts and insurance policies.

A list of important contacts and account information.

Instructions regarding your wishes and final arrangements

Having these matters in order doesn't mean expecting the worse, it means being prepared for whatever life may bring. It assures that your wishes are known and that those who care about you are not left guessing during a difficult time.

If it's been a while since you've reviewed these documents, take this as a gentle reminder to do so. A little preparation today can bring tremendous Peace of Mind to tomorrow.

Don't forget about your information at the LRV office.

Make sure we have the correct phone numbers

Person to contact in an emergency

Address if you go North

People watching your home while you're away.

Don't put it off. The best time to plan is before you need it.

JULY BIRTHDAYS

7/1 Judy Bockrath	Cont.	7/13 Marilene Zinders	7/20 Cliff Fry
7/2 Karla Wright	7/7 Douglas Geise	Debra Perrin	Heidi Crocker
7/3 Dottie Browne	Daniel Rosso	Amy Jensen	7/21 Carl May
Kathryn Bolton	Rob Lewis	Ron Balingit	Carolyn Calkins
Diane Bauer	Gary Dean	7/14 David Bland	Linda Sifford
Beryl Carrier	7/8 Sharon Lewis	Jeff Wright	7/22 Kris Balson
7/4 Ronald Hale	Gretta Byrne	Jennifer Michels	Ken Allen
Cathy Farmer	Denny Young	Phillip Underwood	7/24 Ronald Reynolds
Annie Reilly	7/9 Kathleen Woschanko	7/15 Bob Miller	Mark Lytle
7/5 Curt Gooch	Lois Brown	Ryan Bruursema	Kim Crippen
Carolyn Snodgrass	Nancy Pace	7/16 Mark Rzepka	7/25 Chet Krzyzaniak
7/6 Vicki Hamblen	Joe Hicks	Karen Miller	7/26 Ronald Klimek
Clarence Hoye	7/11 Edward Pippin	John Jacobs	Matthew Chambers
Beverly Pippin	Sheila Tipling	7/17 Wilson Mowbray	7/28 Karin Rettinger
Howard Lisitza	7/12 Sharon House	7/18 Michael Link	7/29 Harold Pack
7/7 Roger Miller	Pat Hale	Nancy Martel	7/30 Barry Kent
Jarrett Miller	Dianne Dawson	7/19 Jim Haskiell	7/31 Jack Howell
Teri Pagani		Trudy Roser	Lynn Holtz
		John DeJohn	Dawn Houseknecht
		David Bultman	Gary Ressler
			Jane Ressler

JULY ANNIVERSARIES

7/4 Bill & Dawn Houseknecht	7/16 Joe & Ruth Hicks	7/23 Raymond & Trudy Roser
7/5 Alan & Lydia Galbraith	7/17 Carl & Donna Micucci	John & Mary Wiegand
7/6 Gary & Jane Ressler	7/18 Mike & Nancy Martel	Harold & Susan Pack
7/7 Gary & Karen Dean	Bruce & Shirley Moore	7/28 Thomas & Tina Link
Rob & Angel Lewis	Ryan & Bonnie Bruursema	Timothy & Jody Hill
7/8 Dennis & Georgia Coon	7/19 George & Minnie Bayer	7/30 Chris & Ellen Martinson
Ray & Sharon Lewis	Jim & Dawn Traina	7/31 David & Sheila Molands
7/11 Clarence & Margie Hoye	Joe & Ruth Hicks	
7/12 Gary & Karen Milliman		
7/16 Don & Barb Corson		



RED HAT LUNCHEON

Red Hat Luncheon will be held at **The Pantry, 2122 US 92, Auburndale, FL** on **Monday July 20th**. We will meet at the clubhouse at **11:00 am** to get loaded and car-pool. Wear your name tag and Red Hat. Any questions, please contact **Shirley Moore** at **904-294-3644**. The sign-up sheet is in the West hall.



COMMUNITY GARDEN

Help needed the 1st Thursday of each month from 10 am–11am. For more information, contact Brenda Renick at 478-342-9898.



JULY DAILY SCHEDULE

EVERY MONDAY

7:45 am Aerobics
9 am Pool Exercises
12 pm Billiards
1 pm Quarter Bingo
6 pm Texas Hold'em
6 pm Pinochle

EVERY TUESDAY

7:45 am Aerobics
9 am Pool Exercise
**10:30 am Line Dance (2nd & 4th
Tue. Only)**
12 pm Billiards
1 pm Crafts

EVERY WEDNESDAY

7:45 am Aerobics
9 am Pool Exercise
9:30 am Card Making (1st
Wed. Only for summer) **CAN-
CELLED FOR JULY**
10 am Bridge
12 pm Billiards
12:45pm Mah Jongs
1 pm Card Bingo
1 pm Dominoes
6 pm Euchre
6 :30 pm No Got

EVERY THURSDAY

8:30 am Koffee
Pool Exercise (after Koffee)
2 pm Billiards
1 pm Quilt Club (1st & 3rd
Thur— Summer months)
6 pm Texas Hold'em

EVERY FRIDAY

7:45 am Aerobics
9 am Pool Exercise
12 pm Billiards
6:30 pm Bunco

EVERY SATURDAY

7:45 am Aerobics
9 am Pool Exercise
12 pm Billiards
6:30 pm Game Night

EVERY SUNDAY

8 am LRV Church

LAKE REGION BOARD OF DIRECTORS

President Carla Byers

president@lakeregionvillage.com
863-669-6735

Vice President Nick Romanow

vicepresident@lakeregionvillage.com
517-375-0941

Secretary Brenda Rollins

secretary@lakeregionvillage.com
586-770-5060

Treasurer Candy Straebel

treasurer@lakeregionvillage.com
856-392-6643

Director Michael Martel

sales@lakeregionvillage.com
860-280-4822

Director Dave Swearingen

mainteance@lakeregionvillage.com
309-370-5000

Director Dawn Houseknecht

facilities@lakeregionvillage.com
518-253-2503

Office open M-F 8am-4pm

Closed for lunch 12-12:45 pm

Sales contact Dulce & Aysha

863-439-1623

OUR NEWSLETTER STAFF

Editor/Advertising

bnmedcare@aol.com

Proof Readers

Distribution

Barb Norsen

321-947-8954

Kim Eickelschulte

Joy Haskiell

Sarah Plummer

Cindy Overlock

Dave Swearingen

Barb Norsen w/ help

SOCIAL CLUB BOARD OF DIRECTORS

President Ellen Wilbarger

V. President Tony Coy

Secretary Kris White

Treasurer Barb Blincoe

Director Claudia

Director Warren Law

Director Gregg Palmer

POOL EXERCISES

Mon-Sat 9am

Thur. 9:30am

BILLIARD LEAGUE

Mon-Sat Noon-2pm

2-2pm

Information for the calendar provided by
the Social Club Vice President. Any
changes or corrections, please contact the
Social Club.

July 2026

Sunday	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday
			1 Card Bingo 1pm Dominoes 1pm NO GOT 6:30	2 Koffee 8am	3 BUNCO 6:30	4 Game Nite 6:30
5 LRV Church 8am	6 Quarter Bingo 1pm Pinochle 6pm	7 Craft Club 1pm POT LUCK 5:30	8 Card Bingo 1pm Dominoes 1pm NO GOT 6:30	9 Koffee 8am	10 BUNCO 6:30	11 Game Nite 6:30
12 LRV Church 8am	13 Quarter Bingo 1pm Pinochle 6pm	14 Line Dance 10:30 Craft Club 1pm	15 Card Bingo 1pm Dominoes 1pm NO GOT 6:30	16 Koffee 8am	17 BUNCO 6:30	18 Game Nite 6:30
19 LRV Church 8am	20 Red Hat Lunch 11:15 Quarter Bingo 1pm Pinochle 6pm	21 Craft Club 1pm	22 Card Bingo 1pm Dominoes 1pm NO GOT 6:30	23 Koffee 8am	24 BUNCO 6:30	25 Game Nite 6:30
26 LRV Church 8am	27 Quarter Bingo 1pm Pinochle 6pm	28 Line Dance 10:30 Craft Club 1pm	29 Card Bingo 1pm Dominoes 1pm NO GOT 6:30	30 Koffee 8am	31 BUNCO 6:30	

2025 Annual Drinking Water Quality Report

Lake Region MHP PWS ID 6530995

We're pleased to provide you with this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source consists of one well that draw water from the Floridian Aquifer. Our water is disinfected with chlorine and delivered to your home.

If you have any questions about this report or concerning your water utility, or want to obtain a copy of this report, please contact Dulce Ibarra at (863) 439-1623. We encourage our valued customers to be informed about their water utility.

Lake Region Mobile Home Park routinely monitors for contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2025. Data obtained before January 1, 2025, and presented in this report are from the most recent testing done in accordance with the above mentioned laws, rules, and regulations.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring, or be the result of oil and gas production or mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. In order to ensure that tap water is safe to drink, the EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

In 2025 the Department of Environmental Protection performed Source Water Assessments on our system. These assessments were conducted to provide information about any potential sources of contamination in the vicinity of our wells. There is no potential source of contamination. The assessment results are available on the FDEP Source Water Assessment and Protection Program website at www.dep.state.fl.us/swapp.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lake Region Mobile Home Park is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water

Stage 1 Disinfectants and Disinfection By-products

Disinfectant or Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL or MRDL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Chlorine: <u>Level Detected</u> is the 2025 monthly average for residual Chlorine; <u>Range of Results</u> is the range of 2025 average monthly Chlorine residual level results (lowest to highest) at the individual sampling sites. Haloacetic Acids / TTHM: <u>Level Detected</u> is the actual sample results taken during the 2024 year.							
Chlorine (ppm)	1/25 - 12/25	N	2.33	1.7-3.3	4	4.0	Water additive used to control microbes
Haloacetic Acids (five) (HAA5) (ppb)	07/24	N	5.84	NA	NA	60	By-product of drinking water disinfection
TTHM [Total trihalomethanes] (ppb)	07/24	N	15.74	NA	NA	80	By-product of drinking water disinfection

Lead and Copper (Tap Water)

Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	AL Exceeded Y/N	90th Percentile Result	No. of sampling sites exceeding the AL	MCLG	AL (Action Level)	Likely Source of Contamination
Copper (tap water) (ppm)	07/24	N	0.025	0	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb)	07/24	N	1.0	0	0	15	Corrosion of household plumbing systems; erosion of natural deposits

Secondary Contaminants

Disinfectant or Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Highest Result	Range of Results	MCLG	MCL	Likely Source of Contamination
Chloride (ppm)	6/24 - 7/24	N	20	19-20	0	250	Natural occurrence from soil leaching
Foaming Agents (ppm)	6/24 - 7/24	N	.069	.053 - .069	0	.5	Pollution from soaps and detergents
Iron (ppm)	6/24 - 7/24	N	.013	NA	0	.3	Natural occurrence from soil leaching
Sulfate (ppm)	6/24 - 7/24	N	15	5.7-15	0	250	Natural occurrence from soil leaching

LCRR

COMPREHENSIVE SERVICE LINE INVENTORY

Submitted by 10/16/2024 (Yes/No) (Y/N)	Submission Date	Violation (Yes/No) (Y/N)	If NOT submitted, WHY? (e.g., ongoing data collection, resource constraints)	If NOT submitted, Provide Completion Timeline
N		Y	Unknown	Unknown

Hotline or at <http://www.epa.gov/safewater/lead>.

In the table below, you may find unfamiliar terms and abbreviations. To help you better understand these terms we've provided the following definitions:

TERM Appearing in TABLE		DEFINITION
Action Level	AL	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Not Applicable	n/a	Does not apply.
Parts per million	ppm	or Milligrams per liter (mg/L) – one part by weight of analyte to one million parts by weight of the water sample.
Parts per billion	ppb	or Micrograms per liter (µg/L) – one part by weight of analyte to one billion parts by weight of the water sample.
Picocuries per liter	pCi/L	- picocuries per liter is a measure of the radioactivity in water.
Maximum Residual Disinfectant Level	MRDL	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal	MRDLG	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Maximum Contaminant Level	MCL	The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal	MCLG	The "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Initial Distribution Evaluation System	IDSE	An important part of the Stage 2 Disinfection Byproducts Rule (DBPR). The IDSE is a one-time study conducted by water systems to identify distribution system locations with high concentrations of trihalomethanes (THMs) and haloacetic acids (HAAs). Water systems will use results from the IDSE, in conjunction with their Stage 1 DBPR compliance monitoring data, to select compliance monitoring locations for the Stage 2 DBPR.
Treatment Technique	TT	A required process intended to reduce the level of a contaminant in drinking water.

Radioactive Contaminants							
**Results in the Level Detected column for radiological contaminants and inorganic contaminants are from individual samples.							
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Alpha emitters (pCi/L)	05/24 - 06/24	N	1.6	1.0-1.6	0	15	Erosion of natural deposits
Radium 226 + 228 or combined radium (pCi/L)	05/24 - 06/24	N	0.9	NA	0	5	Erosion of natural deposits

Inorganic Contaminants							
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Barium (ppm)	06/24	N	0.015	.011-.015	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Mercury (inorganic) (ppb)	06/24	N	.14	NA	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Sodium (ppm)	06/24	N	14	NA	NA	160	Salt water intrusion, leaching from soil